

June 9, 2017

Mr. Darren Parkin
Water Resource Specialist
City of Laramie
P.O. Box C
Laramie, WY 82070

RE: Review of the Site Specific Investigation Report for City of Laramie Jacoby Ridge Trail Project, dated May 18, 2017, prepared by the Trihydro Corporation.

Darren:

WWC Engineering has reviewed the referenced Site Specific Investigation. The conclusion presented in the SSI is that the Jacoby Ridge Trail Project poses low contamination risk to the Casper Aquifer. WWC Engineering concurs with the determination.

WWC has identified a few technical comments on the SSI that are noted below. Whether or not these issues are resolved is up to the City. Resolving them will not change our opinion on aquifer risk.

- Part 3: A description of the scope of work to be completed on the partial access road is not included.
- Part 3: The description is silent on how the parking surface will be graded to drain.
- Part 5: The distance to the Turner #3 well (WSEO Permit Number U.W. P158C) is not stated in the text. Other features were described using approximate distances.
- Part 6: Is there a way to estimate the thickness of Satanka Shale at the project location?
- Part 7: There is no discussion on the parking lot and site drainage.
- We could make several comments on the figures to improve clarity and accuracy, but that is beyond the scope of our review.

Please let me know if you have any questions.

Sincerely,



Murray Schroeder, P.E.
Branch Manager

MS:lw

